



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS  
LANSING

ORLENE HAWKS  
DIRECTOR

## **ORDER OF THE BARRIER FREE DESIGN BOARD**

**Project No.: PR2019BFD-000007**  
**Oh Crepe**  
**Use Group: A-2**

**309 W. Portage St.**  
**Sault Ste. Marie, MI**  
**Chippewa County**

On September 19, 2019, the Barrier Free Design Board reviewed Mr. Zak McClellan's Application for Barrier Free Design Rule Exception for Oh Crepe for relief from the requirements of Section 410.7 of the 2015 Michigan Rehabilitation Code for Existing Buildings and Sections 404.2.3 and 404.2.3.1 of the International Code Council (ICC) A117.1-2009 American National Standard Institute (ANSI), received May 9, 2019 and all supplemental materials. This order is issued pursuant to Section 5(6)(a) of 1966 PA 1 and 1972 PA 230.

**FINDINGS AND CONCLUSIONS:** Mr. McClellan, McClellan Properties, attended the meeting on the above noted date and provided testimony for the review. Following discussion, the Board moved to grant the exception application as submitted.

**THEREFORE,** it is the order of the Board to grant relief from the requirements of Section 410.7 of the 2015 Michigan Rehabilitation Code for Existing Buildings and Sections 404.2.3 and 404.2.3.1 of the International Code Council (ICC) A117.1-2009 American National Standard Institute (ANSI) for a slope not steeper than 1:48, effective September 19, 2019.

cc: Building and Permits Division, BCC  
Sault Ste. Marie Building Department